

TRIPUNITHURA



0484-2780318

MUNICIPAL COUNCIL

email : musectripunithura@gmail.com Fax : 0484 2781033 web site www.thrippunithuramunicipality.in

File No.PH-5010/16

Dated : 15.07.2024

SANITATION CERTIFICATE

This is to certify that Bharatiya Vidya Bhavan's Bhavans Vidya Mandir in Tripunithura Municipality area, Eroor West, inspected by the Health Staff on 11.07.2024. At the time of Inspection the school premises and building were kept clean. Availability of drinking water, health and sanitary facilities are completely satisfactorily.

This certificate is issued only to produce before the CBSE Authority of New Delhi.




CLEAN CITY MANAGER
TRIPUNITHURA MUNICIPALITY
KERALA, INDIA



Report No: ZAL/11/24/TR/22

Page 01 of 02

Date: 18/11/2024

TEST REPORT

Customer Name	THE PRINCIPAL		
Address	BHAVAN'S VIDYAMANDIR EROOR Mob: 8921198771		
Source of Sample	Municipal Tap Water	Date of Sample Receipt	15/11/2024
Sample Code	ZAL/11/24/22	Date of Analysis Started	15/11/2024
Sample By	The Customer	Date of Analysis Completed	16/11/2024
Sample Qty	1 L	Sample Description	Clear liquid

CHEMICAL PARAMETERS

SLNO	PARAMETERS	UNIT	TEST METHOD	RESULT	LIMIT
1	Colour	TCU	IS 3025 -part 4	Agreeable	5
2	Odour	-	IS 3025- Part 5	Agreeable	Agreeable
3	Taste	-	IS 3025- Part 8	-	Agreeable
4	pH	-	IS 3025-Part 11	7.00	6.50 - 8.50
5	Turbidity	NTU	IS 3025-Part 10	1	1
6	Total Dissolved Solids	mg/l	IS 3025-Part 16	120	500
7	Total Hardness as (CaCO ₃)	mg/l	IS 3025 -Part 21	50	200
8	Calcium as (Ca)	mg/l	IS 3025 -Part 40	4.00	75
9	Magnesium as (Mg)	mg/l	IS 3025 -Part 46	9.72	30
10	Total Alkalinity	mg/l	IS 3025 -Part 23	20	200
11	Chloride as (Cl)	mg/l	IS 3025 -Part 32	19.99	250
12	Iron as (Fe)	mg/l	IS 3025 -Part 53	0.196	1
13	Nitrate (as NO ₃)	mg/l	IS 3025 -Part 34	BDL	45
14	Fluoride (as F)	mg/l	IS 3025 -Part 60	0.082	1
15	Sulphate	mg/l	IS 3025 -Part 24	4.28	200
0.2	Residual Chlorine	mg/l	IS 3025- Part 26	0.2	0.2

BDL: Below Detection Limit


NOTE: Precision parameters apply in the determination of the above results. This report shall not be reproduced except without written approval of the Authorized person from the laboratory.

Remarks: All the above parameters are within limit.

No of Test Conducted: 16

End of Report

Verified by



For Zeeland Analytical Laboratory

Authorised Signatory
Haneesh K M

Senior Analyst / Lab in charge
Zeeland Analytical Laboratory



Report No: ZAL/11/24/TR/22

Page 02 of 02

Date: 18/11/2024

TEST REPORT

Customer Name Address	THE PRINCIPAL BHAVAN'S VIDYAMANDIR EROOR Mob: 8921198771		
Source of Sample	Municipal Tap Water	Date of Sample Receipt	15/11/2024
Sample Code	ZAL/11/24/22	Date of Analysis Started	15/11/2024
Sample By	The Customer	Date of Analysis Completed	18/11/2024
Sample Qty	1 L	Sample Description	Clear liquid


MICROBIOLOGY PARAMETERS

SI NO	PARAMETERS	UNIT	METHOD	RESULT	LIMIT
1	Total Coliform	MPN/100ml	IS : 15185-2016	Absent MPN/100ml	Shall not be detectable in any 100 ml sample
2	<i>E.coli</i>	MPN/100ml	IS : 15185-2016	Absent MPN/100ml	

NOTE: Precision parameters apply in the determination of the above results. This report shall not be reproduced except without written approval of the Authorized person from the laboratory.

Remarks:

No of Test Conducted: 2



End of Report

Verified by



For Zeeland Analytical Laboratory

Authorised Signatory
Haneesh K M

Senior Analyst / Lab in charge
Zeeland Analytical Laboratory